REPORT DOCUMENTATION PAGE					Form Approved DMB NO. 0704-0188
Public reporting burden for this collection of inforgathering and maintaining the data needed, and collection of information, including suggestions is Davis Highway, Suite 1204, Arfington, VA 22202	rmation is estimate completing and re- or reducing this bu :-4302, and to the (	d to average 1 hour per re viewing the collection of in rden, to Washington Hea Office of Management and	esponse, including the time for review formation. Send comment regarding dquarters Services, Directorate for in I Budget, Paperwork Reduction Proje	ring instructions this burden es formation Oper ict (0704-0188)	s. searching existing data sources, timates or any other aspect of this reasons and Reports, 1215 Jefferson J. Washington, DC 20503.
AGENCY USE ONLY (Leave blank)	2. REPOR 11/2	T DATE	3. REPORT TYPE A	ND DATES	
4. TITLE AND SUBTITLE	***			5. FUND	ING NUMBERS
Optical Frequency Count	ing and	Synthesis		ŀ	
				DAAH	04-93-G-0399
6. AUTHOR(S)					
Dr. Ngai C. Wong		•			
7. PERFORMING ORGANIZATION NAMES(S) AND ADDRESS(ES) 8. PER					ORMING ORGANIZATION
				REPO	RT NUMBER
Massachusetts Institute of Technology					
77 Massachusetts Avenue	!				
Cambridge, MA 02139-430	7				
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) 10					NSORING / MONITORING NCY REPORT NUMBER
IIS Army Research Office			DPA	31413.9-PH	
P.O. Box 12211			1120	91 11 9 . 7 - 7 11	
Research Triangle Park, NC 2	7709-2211				•
11. SUPPLEMENTARY NOTES					
The views, opinions and/or fin	dings conta	ined in this rep	ort are those of the aut	thor(s) an	id should not be construed as
an official Department of the A	army positi	on, poncy or ae	ecision, unless so design	mated by	other documentation.
12a. DISTRIBUTION / AVAILABILITY ST	ATEMENT			12 b. DI	STRIBUTION CODE
12a. DISTRIBUTION / AVAILABILITY ST	ATEMENT			12 b. Di	STRIBUTION CODE
				12 b. Dis	STRIBUTION CODE
12a. DISTRIBUTION / AVAILABILITY ST					
		A novel method of	optical frequency counting and	synthesis h	as been proposed based
Approved for public release; d		A novel method of	optical frequency counting and rk of optical parametric oscill	synthesis h	as been proposed based
		A novel method of o		synthesis h	as been proposed based scheme utilizes the gen-
Approved for public release; d		A novel method of on a parallel netwo eration of precise f	rk of optical parametric oscill	synthesis h ators. The s	as been proposed based scheme utilizes the genniques to phase lock a
Approved for public release; d		A novel method of on a parallel netwo eration of precise f calibration optical	rk of optical parametric oscill requency ratios by nonlinear	t synthesis h ators. The s optical tech uency stand	as been proposed based scheme utilizes the gen- nniques to phase lock a ard at 9.2 GHz. By op-
Approved for public release; d		A novel method of on a parallel netwo eration of precise f calibration optical erating entirely in	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency to the primary frequency	I synthesis hators. The soptical techniquency stand	nas been proposed based scheme utilizes the genniques to phase lock a ard at 9.2 GHz. By opadvantage of advances
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise f calibration optical serating entirely in in nonlinear crystal	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency the visible to near-IR regions s, detectors and modulators in	i synthesis hators. The soptical techniquency standand taking	nas been proposed based scheme utilizes the gen- nniques to phase lock a ard at 9.2 GHz. By op- advantage of advances ral region, an optical-to-
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise f calibration optical erating entirely in in nonlinear crystal microwave frequence	rk of optical parametric oscill frequency ratios by nonlinear frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the cyclain can be operated effici	I synthesis hators. The soptical techniquency standand taking in this spectre ently and control of the synthesis in the spectre of the synthesis in the synthes	as been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By opadvantage of advances al region, an optical-to-proposed
Approved for public release; d	istribution	A novel method of on a parallel netwo eration of precise of calibration optical erating entirely in in nonlinear crystal microwave frequency frequency chain car	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency the visible to near-IR regions s, detectors and modulators in the cy chain can be operated efficing the be used to provide the high	i synthesis hators. The soptical techniquency stand and taking in this spectre ently and conest frequences.	as been proposed based scheme utilizes the gen- nniques to phase lock a ard at 9.2 GHz. By op- advantage of advances ral region, an optical-to- ompactly. The proposed cy accuracy in the visi-
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise of calibration optical erating entirely in in nonlinear crystal microwave frequency frequency chain car	rk of optical parametric oscill frequency ratios by nonlinear frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the cyclain can be operated effici	i synthesis hators. The soptical techniquency stand and taking in this spectre ently and conest frequences.	as been proposed based scheme utilizes the gen- nniques to phase lock a ard at 9.2 GHz. By op- advantage of advances ral region, an optical-to- ompactly. The proposed cy accuracy in the visi-
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel network of calibration optical derating entirely in in nonlinear crystal microwave frequency chain calible for applications	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency the visible to near-IR regions s, detectors and modulators in the cy chain can be operated efficing the be used to provide the high	I synthesis hators. The soptical techniquency standand taking in this spectreently and conest frequendards, presented in the spectra of the s	as been proposed based scheme utilizes the genniques to phase lock a ard at 9.2 GHz. By opadvantage of advances al region, an optical-to-proposed cy accuracy in the visicision spectroscopy, and
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise of calibration optical of erating entirely in in nonlinear crystal microwave frequency frequency chain can ble for applications measurements of fu	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in cy chain can be operated efficing be used to provide the high such as optical frequency sta	i synthesis hators. The soptical techniquency stand and taking in this spectre ently and conest frequency and cone	has been proposed based scheme utilizes the gen- niques to phase lock a sard at 9.2 GHz. By op- advantage of advances ral region, an optical-to- proposed cy accuracy in the visi- cision spectroscopy, and mod is applicable to pro-
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel network of calibration optical derating entirely in in nonlinear crystal microwave frequency chain calible for applications measurements of funducing a commercial	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the used to provide the high such as optical frequency standamental constants. Moreover	I synthesis hators. The soptical technency standand taking in this spectreently and conest frequential and taking in this spectreently and conest frequential and synthesize and synthesize in the method of the synthesize in the s	as been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By opadvantage of advances al region, an optical-to-perpactly. The proposed cy accuracy in the visicision spectroscopy, and and is applicable to proceer for use in laboratory
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel network of calibration of precise of calibration optical derating entirely in in nonlinear crystal microwave frequency chain carble for applications measurements of fuducing a commerciand field environments.	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the used to provide the high such as optical frequency standamental constants. Moreoval optical frequency counter a ents. In addition, the propose	i synthesis hators. The soptical technency stand and taking in this spectrently and conest frequency and ards, presert, the method synthesized frequency	has been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By opadvantage of advances ral region, an optical-to-proposed by accuracy in the visicision spectroscopy, and and is applicable to proposer for use in laboratory counter can be used to
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise for calibration optical erating entirely in in nonlinear crystal microwave frequency chain carble for applications measurements of further ducing a commerciand field environments of provide accurate from the carble of the car	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency to the primary frequency in the visible to near-IR regions s, detectors and modulators in cy chain can be operated efficing be used to provide the high such as optical frequency standamental constants. Moreover all optical frequency counter a cents. In addition, the propose equency markers in the important of the propose equency markers in the important of the propose equency markers in the important of the propose of the primary frequency of the propose of the prop	I synthesis hators. The soptical technency standand taking in this spectre ently and conest frequency and synthesized frequency tant 1.55-µm	as been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By oparadvantage of advances al region, an optical-to-perpactly. The proposed cy accuracy in the visicision spectroscopy, and and is applicable to propose for use in laboratory counter can be used to a optical communication
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise of calibration optical derating entirely in in nonlinear crystal microwave frequency chain carble for applications measurements of fuducing a commerciand field environments of fuducing field env	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the used to provide the high such as optical frequency standamental constants. Moreoval optical frequency counter a ents. In addition, the propose equency markers in the important of this work has been to detect the social frequency courses and the social frequency counter an	is synthesis hators. The soptical technency stand and taking in this spectre ently and conest frequency dark 1.55- $\mu$ m evelop the v	as been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By opadvantage of advances al region, an optical-to-ompactly. The proposed cy accuracy in the visicision spectroscopy, and nod is applicable to proposer for use in laboratory counter can be used to a optical communication various technologies that
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise of calibration optical derating entirely in in nonlinear crystal microwave frequency chain carble for applications measurements of fuducing a commerciand field environments of fuducing field env	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency to the primary frequency in the visible to near-IR regions s, detectors and modulators in cy chain can be operated efficing be used to provide the high such as optical frequency standamental constants. Moreover all optical frequency counter a cents. In addition, the propose equency markers in the important of the propose equency markers in the important of the propose equency markers in the important of the propose of the primary frequency of the propose of the prop	is synthesis hators. The soptical technency stand and taking in this spectre ently and conest frequency dark 1.55- $\mu$ m evelop the v	has been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By oparadvantage of advances and region, an optical-to-perparently. The proposed cy accuracy in the visicision spectroscopy, and nod is applicable to propose for use in laboratory counter can be used to a optical communication various technologies that withesis apparatus.
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise of calibration optical derating entirely in in nonlinear crystal microwave frequency chain carble for applications measurements of fuducing a commerciand field environments of fuducing field env	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the used to provide the high such as optical frequency standamental constants. Moreoval optical frequency counter a ents. In addition, the propose equency markers in the important of this work has been to detect the social frequency courses and the social frequency counter an	is synthesis hators. The soptical technency stand and taking in this spectre ently and conest frequency dark 1.55- $\mu$ m evelop the v	as been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By opadvantage of advances al region, an optical-to-ompactly. The proposed cy accuracy in the visicision spectroscopy, and nod is applicable to proposer for use in laboratory counter can be used to a optical communication various technologies that
Approved for public release; d  13. ABSTRACT (Maximum 200 words)	istribution	A novel method of on a parallel netwo eration of precise of calibration optical derating entirely in in nonlinear crystal microwave frequency chain carble for applications measurements of fuducing a commerciand field environments of fuducing field env	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the used to provide the high such as optical frequency standamental constants. Moreoval optical frequency counter a ents. In addition, the propose equency markers in the important of this work has been to detect the social frequency courses and the social frequency counter an	is synthesis hators. The soptical technency stand and taking in this spectre ently and conest frequency dark 1.55- $\mu$ m evelop the v	has been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By oparadvantage of advances and region, an optical-to-perparently. The proposed cy accuracy in the visicision spectroscopy, and nod is applicable to propose for use in laboratory counter can be used to a optical communication various technologies that withesis apparatus.
Approved for public release; d  13. ABSTRACT (Maximum 200 words)  DITO QUALITY 12:35	Estribution	A novel method of on a parallel netwo eration of precise of calibration optical erating entirely in in nonlinear crystal microwave frequency chain carble for applications measurements of fuducing a commerci and field environment provide accurate frequency. The main for are needed for a precise of the carbon o	rk of optical parametric oscill requency ratios by nonlinear frequency to the primary frequency to the primary frequency to the visible to near-IR regions s, detectors and modulators in the used to provide the high such as optical frequency standamental constants. Moreoval optical frequency counter a ents. In addition, the propose equency markers in the important of this work has been to detect the social frequency courses and the social frequency counter an	is synthesis hators. The soptical techniquency stand and taking in this spectre ently and conest frequency and synthesized frequency tant 1.55-µm evelop the venting and synthesized synthesized frequency tant 1.55-µm evelop the venting and synthesized synthesized frequency tant 1.55-µm evelop the venting and synthesized synthesiz	as been proposed based scheme utilizes the genniques to phase lock a and at 9.2 GHz. By oparadvantage of advances al region, an optical-to-ompactly. The proposed cy accuracy in the visicision spectroscopy, and nod is applicable to proposer for use in laboratory counter can be used to a optical communication various technologies that withesis apparatus.

## FINAL REPORT

Optical Frequency Counting and Synthesis

U. S. Army Research Office Grant DAAH04-93-G-0399

Covering the Period August 1, 1993 – September 30, 1996

Submitted by

Ngai C. Wong Principal Investigator

November 27, 1996

Research Laboratory of Electronics Massachusetts Institute of Technology Cambridge, Massachusetts 02139

# Contents

1	Stat	tement of Work	2			
2	earch Summary	3				
	2.1	Optical Parametric Oscillator Technology	3			
	2.2	Nonlinear Optical Measurements	4			
	2.3	Optical-to-Microwave Frequency Chain	5			
	2.4	Outlook	6			
		References	8			
3	3 Personnel					
4	List	of Publications	11			
5	5 List of Meeting Presentations					
6	Pat	ent.	15			

#### 1 Statement of Work

A novel method of optical frequency counting and synthesis has been proposed based on a parallel network of optical parametric oscillators. The scheme utilizes the generation of precise frequency ratios by nonlinear optical techniques to phase lock a calibration optical frequency to the primary frequency standard at 9.2 GHz. By operating entirely in the visible to near-IR regions and taking advantage of advances in nonlinear crystals, detectors and modulators in this spectral region, an optical-to-microwave frequency chain can be operated efficiently and compactly. The proposed frequency chain can be used to provide the highest frequency accuracy in the visible for applications such as optical frequency standards, precision spectroscopy, and measurements of fundamental constants. Moreover, the method is applicable to producing a commercial optical frequency counter and synthesizer for use in laboratory and field environments. In addition, the proposed frequency counter can be used to provide accurate frequency markers in the important 1.55- $\mu$ m optical communication band. The main focus of this work has been to develop the various technologies that are needed for a prototype optical frequency counting and synthesis apparatus.

## 2 Research Summary

Under ARO Grant DAAH04-93-G-0399 "Optical Frequency Counting and Synthesis," we have pursued a vigorous program of experimental research on optical frequency counting and its associated technologies. In this final report we shall summarize the principal results that we have obtained. Complete details can be found in the journal articles and meeting presentations that have been produced during the course of our research program.

## 2.1 Optical Parametric Oscillator Technology

An optical parametric oscillator (OPO) is a nonlinear optical device that converts an input pump into two subharmonics whose frequency sum equals the pump frequency. OPOs are highly efficient and are tunable over a broad spectral range, making them a superior tunable light source [1]. OPOs play an important role in this research program as highly stable and precisely tunable optical frequency dividers [2, 3, 4]. We have developed a number of techniques to improve the stability and tunability of cw doubly resonant OPOs.

In a doubly resonant OPO the optical cavity is resonant with the signal and idler waves simultaneously and therefore the OPO is in general not very stable. We have developed a dual-cavity OPO in which the orthogonally polarized signal and idler are internally separated by a polarizing beam splitter so that each subharmonic wave is resonated in its own separate cavity. In this way, the signal and idler cavities can be individually tuned and therefore continuous frequency tuning becomes feasible. We demonstrated a dual-cavity OPO with a continuous tuning range of 1 GHz, about a 100-fold improvement relative to a single-cavity OPO [5].

In the study of the dual-cavity OPO, we have noted the possibility of mixing

the orthogonally polarized signal and idler waves by use of a polarization-sensitive intracavity element [5]. Subsequently we have developed a self-phase locked type-II phase-matched OPO that takes advantage of this mechanism for polarization mixing. By inserting a quarter-wave plate in the optical cavity, the signal and idler waves experience a polarization rotation after passing through the waveplate twice in a cavity roundtrip. In this way, their polarizations are mixed and this provides a means for self-injection locking when the OPO is operated near frequency degeneracy. We have observed self-phase locking to occur when the frequency separation between the signal and idler is less than 300 MHz and the self-phase locked OPO was found to be stable [6, 7]. This is the first time that self-phase locking in a type-II phase matched OPO has been demonstrated. This technique is particularly useful in optical frequency division because it eliminates the use of complicated servo locking circuits and the self-phase locked OPO is more stable than our previous externally phase locked OPOs [3].

## 2.2 Nonlinear Optical Measurements

We have made a number of new measurements that provide useful information on the phase noise of an OPO and on a new crystal cesium titanyl arsenate. For optical frequency counting, an OPO frequency divider should have very low phase noise in order that the optical-to-microwave frequency chain can be phase coherent. In an externally phase locked OPO at a signal-idler beat frequency of 30 MHz, we demodulated the beat signal and measured the in-phase and quadrature-phase phase noise and compared with our theoretical estimates [8, 5]. We have observed for the first time the phase diffusion noise of an OPO that is far above the shot noise level at low rf frequencies, as expected. This work lays the foundation for further investigation

into the control and study of the fundamental noise limit of an OPO for use in high precision measurements.

We have made difference-frequency measurements in a cesium titanyl arsenate (CTA) crystal that is an isomorph of KTP [9, 10]. CTA is type-II phase matched, has a large temperature bandwidth, and is phase matchable at wavelengths longer than KTP. In particular, noncritical phase matching is possible for the interaction: 798 nm + 1596 nm  $\rightarrow$  532 nm, which has a 3:1 frequency ratio. By using inputs from a krypton ion laser at 531 nm and a tunable Ti:sapphire laser centered at 800 nm, we obtained tunable radiation from 1.57 to 1.65  $\mu$ m with a single-pass output power of 1  $\mu$ W. When the system was configured as a doubly resonant cavity, 100  $\mu$ W of output power was obtained. We have thus verified the phase matching angle of CTA for 3:1 frequency division and also determined its effective nonlinear coefficient at 2.30 pm/V.

## 2.3 Optical-to-Microwave Frequency Chain

In 1992 we proposed to realize an optical-to-microwave frequency chain by use of a parallel network of OPOs that are related at some fixed frequency ratios. The method should allow one to accurately measure any optical frequency from the UV to the near-IR relative to the Cs primary frequency standard [11]. This scheme is rather complicated requiring many stages of OPOs operating in unison. It is therefore useful to devise a simpler and more accessible system to realize an optical frequency chain with the same advantages of operating only in the visible and near-IR spectral regions. By utilizing a second calibration laser, we have proposed a new method of achieving optical frequency counting by using fewer number of OPOs and by generating a frequency ratio of (4/9) [12].

A 3:1 frequency divider can be realized in the following way. The first step is to generate from a  $3\omega$  input pump two outputs  $2\omega + \delta$  and  $\omega - \delta$ . Difference-frequency mixing for the two outputs then yields  $\omega + 2\delta$ . By measuring the beat frequency  $3\delta$  between  $\omega - \delta$  and  $\omega + 2\delta$  and setting  $\delta = 0$ , an exact 3:1 frequency ratio is obtained [13].

In the new scheme of a two-laser OPO network, a doubled-YAG 532-nm pump at  $\omega$  generates a  $(2/3)\omega$  output at 798 nm, to which a second laser is phase locked. This second laser pumps another OPO to generate an output at a (2/3) frequency ratio at 1197 nm. This output frequency is exactly equal to  $(4/9)\omega$ . By measuring the frequency difference between the  $(4/9)\omega$  and  $(1/2)\omega$  (YAG laser), which is  $\sim$ 31 THz, relative to the Cs clock,  $\omega$  is absolutely determined. The difference frequency measurement can be made by using a set of  $\sim$ 5 OPOs in parallel and by employing terahertz optical frequency combs [14].

#### 2.4 Outlook

Together with research performed under other programs, we have investigated and demonstrated a number of important technologies that bring us to the threshold of demonstrating a two-laser based optical-to-microwave frequency chain. Under this grant, we have measured the phase noise of an OPO and demonstrated a novel self-phase locked OPO. A dual-cavity OPO has been shown to offer great promise as a continuously tunable light source. We have also studied the phase matching characteristics of a CTA crystal for 3:1 frequency division.

Under other research programs, we have now demonstrated terahertz optical frequency comb generation with a span of 4.3 THz which suggests that difference-frequency measurements at several THz is now feasible. We are fabricating peri-

odically poled lithium niobate (PPLN) wafers that can be quasi-phase matched for nonlinear frequency conversion at user-specified wavelengths. This solves an important material problem in the realization of an optical frequency chain that requires the generation of many optical frequencies at various spectral regions. We have also built a tunable diode laser and injection locked diode amplifier with an output power of 500 mW at 790 nm that serves as the second laser in our scheme. The diode laser system replaces the Ti:sapphire system we used earlier and makes it possible to obtain a compact all-solid-state system. We have high hopes that further work in this area will yield tremendous improvement in our optical frequency measurement and synthesis capability for a variety of applications in commercial, research, and military ventures.

## References

- [1] R. L. Byer, in *Quantum Electronics: A Treatise*, H. Rabin and C. L. Tang, eds. (Academic, New York, 1975), pp. 587-702.
- [2] N. C. Wong, "Optical frequency division using an optical parametric oscillator," Opt. Lett. 15, 1129-1131 (1990).
- [3] D. Lee and N. C. Wong, "Tunable optical frequency division using a phase-locked optical parametric oscillator," Opt. Lett. 17, 13-15 (1992).
- [4] D. Lee and N. C. Wong, "Stabilization and tuning of a doubly resonant optical parametric oscillator," J. Opt. Soc. Am. B 10, 1659–1667 (1993).
- [5] Dicky Lee, "Optical parametric oscillators and precision frequency measurements," Ph.D. thesis, M.I.T., 1996.
- [6] Elliott J. Mason, "Self-phase locking in a type-II phase matched optical parametric oscillator," master thesis, M.I.T., 1996.
- [7] N. C. Wong, E. Mason, and P. Nee, "Metrological applications of frequency conversion in  $\chi^{(2)}$  media," Quantum Semiclass. Opt., to appear.
- [8] D. Lee and N. C. Wong, "Quantum phase diffusion noise measurements in a cw optical parametric oscillator," Coherence and Quantum Optics VII, Eberly, Mandel, and Wolf, eds., (Plenum Press, 1996), pp. 423-424.
- [9] B. Lai, N. C. Wong, and L. K. Cheng, "Continuous-wave tunable light source at 1.06 μm by difference-frequency mixing in CsTiOAsO<sub>4</sub>," Opt. Lett. 20, 1779– 1781 (1995).

- [10] Bobby Y. F. Lai, "A tunable light source at 1.6  $\mu$ m by difference-frequency mixing in cesium titanyl arsenate," master thesis, M.I.T., 1995.
- [11] N. C. Wong, "Optical frequency counting from the UV to the near IR," Opt. Lett. 17, 1155-1157 (1992).
- [12] N. C. Wong, "Optical-to-microwave frequency chain utilizing a two-laser-based optical parametric oscillator network," Appl. Phys. B 61, 143-149 (1995).
- [13] N. C. Wong, B. Lai, P. Nee, and E. Mason, "Experimental progress toward realizing a 3:1 optical frequency divider," Proceedings Fifth Symposium on Frequency Standards and Metrology, Bergquist, ed., (World Scientific, 1996), pp. 319-326.
- [14] L. R. Brothers, D. Lee, and N. C. Wong, "Terahertz optical frequency comb generation using a resonant phase-velocity-matched electro-optic modulator," Opt. Lett. 19, 245-247 (1994).

## 3 Personnel

Research under Contract DAAH04-93-G-0399 was carried out by:

Dr. Ngai C. Wong, Principal Investigator

Dicky Lee, Graduate Student

Ph.D., Physics, MIT, February 1996

Bobby Lai, Graduate Student

S.M., Electrical Engineering & Computer Science, MIT, January 1995.

### 4 List of Publications

The following journal articles report research performed under Grant DAAH04-93-G-0399:

- L. R. Brothers, D. Lee, and N. C. Wong, "Terahertz optical frequency comb generation and phase locking of an optical parametric oscillator at 665 GHz," Opt. Lett. 19, 245-247 (1994).
- N. C. Wong, "Optical-to-microwave frequency chain utilizing a two-laser-based optical parametric oscillator network," Appl. Phys. B 61, 143-149 (1995).
- B. Lai, N. C. Wong, and L. K. Cheng, "Continuous-wave tunable light source at 1.06 μm by difference-frequency mixing in CsTiOAsO<sub>4</sub>," Opt. Lett. 20, 1779–1781 (1995).
- D. Lee and N. C. Wong, "Quantum phase diffusion noise measurements in a cw optical parametric oscillator," Coherence and Quantum Optics VII, Eberly, Mandel, and Wolf, eds., (Plenum Press, 1996), pp. 423-424.
- N. C. Wong, B. Lai, P. Nee, and E. Mason, "Experimental progress toward realizing a 3:1 optical frequency divider," Proceedings Fifth Symposium on Frequency Standards and Metrology, Bergquist, ed., (World Scientific, 1996), pp. 319-326.
- 6. N. C. Wong, E. Mason, and P. Nee, "Metrological applications of frequency conversion in  $\chi^{(2)}$  media," Quantum Semiclass. Opt., to appear.

- 7. D. Lee and N. C. Wong, "Tuning characteristics of a cw dual-cavity KTP optical parametric oscillator," in preparation.
- 8. E. J. Mason and N. C. Wong, "Self-phase locking in a type-II phase matched optical parametric oscillator," in preparation.

## 5 List of Meeting Presentations

The following meeting presentations reported research performed under Grant DAAH04-93-G-0399:

- N. C. Wong, D. Lee, and L. R. Brothers, "Optical frequency counting based on parametric downconversion," Digest of International Symposium on Atomic Frequency Standards and Coherent Quantum Electronics, Nara, Japan, August 1993, pp. 14-17.
- D. Lee, N. C. Wong, and L. R. Brothers, "Frequency tuning and stabilization of a KTP optical parametric oscillator," Digest of Optical Society of America Annual Meeting, Toronto, Canada, October 1993, p. 85.
- N. C. Wong, D. Lee, and L. R. Brothers, "Continuous-wave phase-locked optical parametric oscillator as a tunable source for terahertz radiation," SPIE Proceedings of Nonlinear Opitcs for High-Speed Electronics, Los Angeles, CA, January, 1994, vol. 2145, pp. 190-199.
- 4. N. C. Wong and D. Lee, "Frequency tuning and phase locking of an ultrastable doubly resonant optical parametric oscillator," Optical Society of America Proceedings on Advanced Solid-State Lasers, Salt Lake City, UT, February 1994, pp. 432-434.
- N. C. Wong, D. Lee, and L. R. Brothers, "Optical frequency measurement and synthesis using nonlinear optical techniques," Digest of Conference on Lasers and Electro-Optics, Anaheim, CA, May, 1994, p. 200.

- D. Lee and N. C. Wong, "Tuning characteristics of a cw dual-cavity KTP optical parametric oscillator," Digest of Conference on Lasers and Electro-Optics, Anaheim, CA, May, 1994, pp. 200-201.
- D. Lee and N. C. Wong, "Quantum phase diffusion noise measurements in a cw optical parametric oscillator," Proceedings of Coherence and Quantum Optics VII, Eberly, Mandel, and Wolf, eds., (Plenum Press, 1996), pp. 423-424.
- 8. N. C. Wong, B. Lai, P. Nee, and E. Mason, "Experimental progress toward realizing a 3:1 optical frequency divider," Proceedings of Fifth Symposium on Frequency Standards and Metrology, Bergquist, ed., (World Scientific, 1996), pp. 319-326.
- 9. N. C. Wong, E. Mason, and P. Nee, "Metrological applications of frequency conversion in  $\chi^{(2)}$  media," Les Houches Workshop on Second Order Nonlinear Optics: from Fundamentals to Applications, Les Houches, France, April 1996.
- E. J. Mason and N. C. Wong, "Self-phase locking in a type-II phase-matched optical parametric oscillator," submitted for presentation at Conference on Lasers and Electro- Optics, Baltimore, MD, May 1997.

# 6 Patent

 Ngai C. Wong, "Optical Frequency Counter/Synthesizer Apparatus," U.S. Patent No. 5,233,462, issued Aug. 3, 1993.